

SMMC – Corridor Expansion

Issue for Bid RFI's

May 3, 2010

1. Section 012300 – Alternates – The 4/16 section alternates describe what appear to be alternates from another project. 4/22 addendum did not update this section. Please clarify.

This project has no alternates, section 012300 was deleted in Addendum No. 1, attached.

2. Bid Form – Are we to use our letterhead?

A bid form will be provided (forthcoming). You may print the bid form on your letterhead if you would like, it is not required.

3. 0640023- Arch millwork – section given but what is scope?

There is no millwork in this bid.

4. Roofing – Spec sections list “Green roof” components but bldg X-sections indicate R-1 3 ply Mod Bitum & not “Green Roofing” – please clarify.

Roofing scope should include the 3 ply modified bitumen roof. The built-up, vegetated roof R-1, as detailed in detail 8/A.503 is not in this contract. All details drawn are in anticipation for a future vegetated roof.

5. Electrical – Please provide location of ATS-4.

Approximate location will be in the vicinity of ‘EDSBC’ shown on detail 4/E2.01

6. Electrical – Please provide location of EDSBC.

‘EDSBC’ is shown on detail 4/E2.01. It is indicated at ‘EDSC’.

7. Electrical – Please provide routing for relocated conduits referenced on E2.01 – relocate 3” & 1” conduit for ATS-1.

Rerouting/reworking of conduit is required to accommodate new duct work shown on 2/H1.00 and 10/H3.00.

8. Is a standard AIA contract to be used for this bid?

Yes, a standard AIA contract will be used.